WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47338
Permit No.
Basin
NOTICE OF INTENT NO. 14785

1. OWNER Dick Hoth
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2521 S Winchester Ave.

2. LOCATION NE ¼ SW ¼ Sec. 29 T 20-S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-251-26 (Parcel No.) Calvada Valley Unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray clay		4	8	4
Brown clay		8	12	4
Limestone		12	24	12
Brown clay/caliche		24	46	22
Brown clay	X	46	64	18
Brown clay/caliche		64	88	24
Brown clay		88	107	19
Brown clay/caliche	X	107	140	33

RECEIVED
MAR 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Feb. 27, 1995
Date completed Feb. 27, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	½

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation 1/Torch Cut - 1/Factory Cut
Size perforation ½"width 8"long - 1/8"width 3"long-
From 100 feet to 140 feet 8 rolls
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date March 2, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627