

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24225

1. OWNER Mike & Toni McCormick ADDRESS AT WELL LOCATION 1617 S. Deer Run Rd Carson City NV 89701
 MAILING ADDRESS 720 Esau St. Minden NV 89440
 2. LOCATION NE 1/4 NE 1/4 Sec 23 T. 15 S. R. 20 E Carson County
 PERMIT NO. 10-093-04 Parcel No. _____ Subdivision Name Pinon Hills
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	3	3
Coarse Gravels and Sands		3	27	24
Volcanic Sands		27	50	23
Volcanic Gravels		50	165	115
Sands Volcanic Clay		165	200	35
Volcanic Gravels	xxx	200	250	50

94 NOV 10 P 1:25

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/4 Inches To 50 Feet
 From 9 7/8 Inches To 250 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.198	0	250

Perforations:
 Type perforation Mill Slot
 Size perforation 3X 3/32
 From 250 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 30 feet to 250 feet

9. WATER LEVEL
 Static water level 150' feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature Hot °F Quality Good

Date started 11-3, 1994
 Date completed 11-5, 1994

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>257</u>	<u>30</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A. H. Pump Company Contractor
 Address 5551 Hwy 506 #3 Carson City NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Hick
 By driller performing actual drilling on site or contractor
 Date 11-5-94