WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR USE ONLY
Log No. 407370
Permit No.
Basin 087

NOTICE OF INTENT NO. 26172

1. OWNER WASHOE CO. DPT. OF PUBLIC WORKS
MAILING ADDRESS 1001 E 9TH ST. RENO NV.
ADDRESS AT WELL LOCATION WASHOE CO. MAINTENANCE YARD 5101 CONSTELL LN. RENO, NV.

2. LOCATION SW 1/4 SE 1/4 Sec. 20 T. 19 N/S R. 20 E. WASHOE County
PERMIT NO. OLD MW 7469
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG #2

Material	Water Strata	From	To	Thickness
ON 10/25/94 I				
FOUND THE MONITORING				
WELL TO BE IN				
GOOD CONDITION.				
AFTER I REMOVED				
THE TOP I DRILLED				
THE CASING OUT				
TO 15'. I THEN				
PRESSURE GROUTED				
WITH NEAT CEMENT				
FROM 15' TO 0'				

Date started 10/25, 19 94
Date completed 10/25, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 15' Feet Depth Cased 15' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0' Feet	15' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	40	PVC	0'	15'

Perforations:
Type perforation FACTORY
Size perforation .020
From 10' feet to 15' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 15'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 11.5' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling Contractor
Address 1635 Belford rd Contractor
Reno, NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34505
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1025
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627