WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47395
Permit No.
Basin 162

NOTICE OF INTENT NO. 14558

1. OWNER Larry Tippetts
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4001 E. McGraw

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-284-15 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	11	6
Calichie		11	13	2
Clay		13	38	25
Calichie		38	43	5
Clay		43	51	8
Calichie		51	54	3
Clay		54	72	18
Calichie	WB	72	77	5
Clay		77	89	12
Calichie	WB	89	92	3
Clay		92	106	14
Calichie	WB	106	108	2
Clay		108	115	7
Calichie	WB	115	117	2
Clay		117	122	5
Calichie	WB	122	124	2
Clay		124	130	6
Calichie	WB	130	132	2
Clay		132	136	4
Calichie	WB	136	138	2
Clay		138	140	2

Date started January 25, 19 95
Date completed January 27, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 2/16/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627