WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

RECEIVED APR 11 1995 Div. of Water Resources

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47399 in Book
Permit No.
Basin 162

NOTICE OF INTENT NO. 14606

1. OWNER Cliff Whisenhunt
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4830 Sa Vay

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 21 N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-292-27 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Calichie		8	11	3
Clay		11	21	10
Calichie		21	24	3
Clay		24	29	5
Calichie		29	43	14
Clay		43	54	11
Calichie		54	57	3
Clay		57	68	11
Calichie	WB	68	74	6
Clay		74	79	5
Calichie	WB	79	82	3
Clay		82	95	13
Calichie	WB	95	97	2
Clay		97	102	5
Calichie	WB	102	105	3
Clay		105	111	6
Calichie	WB	111	113	2
Clay		113	121	8
Calichie	WB	121	124	3
Clay		124	128	4
~~Calichie~~	~~WB~~	~~128~~		
Limestone	WB	128	137	9
Clay		137	140	3

Date started 3/31, 19 95
Date completed 3/31, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 4/4/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627