

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27242

1. OWNER Chuck Overbay ADDRESS AT WELL LOCATION 20255 Coldsprings
 MAILING ADDRESS 3240 Sun Cloud Cir
Reno, Nv 89506 Reno, NV 89506
 2. LOCATION NW 1/4 SW 1/4 Sec 20 T 21 N N/S R 18 E Washoe County
 PERMIT NO. State 59052 087-283-01 Coldsprings Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil with gravels		0	2	2
Dark Brown Clay		2	6	4
Brown Sandy Clay		6	18	12
Brown Sandy Clay with Gravels		18	37	19
Brown Clay		37	69	32
Softzone (fine sands)	x	69	78	7
Brown Sandy Clay		78	87	9
Softzone (5 GPM) at 105ft had 5GPM with Sands went deeper	x	87	92	5
Brown Sandy Clay		92	117	35
Softzone	x	117	122	5
Brown Sandy Clay		122	125	3

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 125 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	125

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 125 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV, 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 25, 1995

Date started January 20, 1995, 19____
 Date completed January 20, 1995, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		