


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



NOTICE OF INTENT NO. 14274

1. OWNER Harry Stackins ADDRESS AT WELL LOCATION Cover lot south side off Hwy 322
 MAILING ADDRESS STEWART Valley Coll. * Murphy PUNA
 2. LOCATION SW 1/4 SW 25 T 20 N/S R 52 E Nye County
 PERMIT NO. 27-581-31 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
 4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Stock, Test, Monitor, Stock
 5. WELL TYPE: Cable, Rotary, RVC, Air, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	60	60
Brown lime Stone		60	65	5
Green Clay		65	68	3
Red Sand		68	78	10
Brown Clay	90	78	110	32

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14 3/4 Inches To 110 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 5/8</u>	<u>25</u>	<u>1 9/16</u>	<u>0</u>	<u>110</u>

Perforations:
 Type perforation Tracer
 Size perforation 7/16 x 4"
 From 90 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
 APR 12 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Surface Seal: Yes No Seal Type: Neat Cement, Cement Grout, Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped, Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 66 °F Quality _____

Date started 3-25, 1995
 Date completed 4-1, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>100</u>	<u>2</u>	<u>30</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce Robinson Contractor
 Address P.O. 8307 Contractor
PUNA 89041
 Nevada contractor's license number issued by the State Contractor's Board 15972
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
 Signed Bruce Robinson
 By driller performing actual drilling on site or contractor
 Date 4-11-95