



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14702

1. OWNER Roland Rysavy ADDRESS AT WELL LOCATION 450 W. Jarvis St.
 MAILING ADDRESS _____

2. LOCATION NW 1/4 NE 1/4 Sec. 28 T 19-S N/S R 53 E Nye County
 PERMIT NO. 29-882-18 Bell Vista, Unit 3, Blk. 4,
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Sandy loam		4	15	11
Brown clay		15	36	21
Brown clay/caliche		36	82	46
Brown clay	X	82	103	21
Brown clay/caliche		103	126	23
Brown clay		126	158	32
Brown clay/caliche	X	158	200	42

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 200 Feet
12 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
 Type perforation 1/Torch Cut - 1/Factory Cut
 Size perforation 1/4" width 8" long - 1/8" width 3" long - 8 rolls
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 73 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC
 Address P.O. Box 56
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 4, 1995

Date started March 27 1995
 Date completed March 27 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

RECEIVED
 APR 14 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV