WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47469
Permit No.
Basin 162

NOTICE OF INTENT NO. 13177

1. OWNER Hubert & Linda LeRoy
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 19-S N/S R. 53 E. Nye County
PERMIT NO. APN 29-387-05 (Issued by Water Resources) 136 (Parcel No.) Crystalaire Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Sandy Clay		4	20	16
Grey Clay		20	45	25
White Clay		45	96	51
Brown Clay/Gravel	x	96	120	24
Hard Lime		120	125	5
Brown Clay/Gravel	x	125	150	25
Hard Lime		150	156	6
Grey Sandy Clay/ Sand Streaks	x	156	180	24

RECEIVED
APR 17 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 28, 1995
Date completed March 30, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	180 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18lbs.	.188	0	180

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 Pahrump, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date 4-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627