WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47470
Permit No.
Basin 162

NOTICE OF INTENT NO. 14582

1. OWNER Kathleen Bishop
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3090 Florenza

2. LOCATION SE ¼ SW ¼ Sec. 28 T. 19S N/S R. 53 E/W Nye County
PERMIT NO. (Issued by Water Resources) 27-132-09 (Parcel No.) Rancho Paradise (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	10	10
Calichie		10	13	3
Clay		13	17	4
Calichie		17	22	5
Clay		22	29	7
Calichie		29	40	11
Clay		40	46	6
Calichie		46	48	2
Clay		48	54	6
Calichie	WB	54	69	15
Clay		69	77	8
Calichie	WB	77	79	2
Clay		79	94	15
Calichie	WB	94	98	4
Clay		98	101	3
Calichie	WB	101	107	6
Clay		107	118	11
Calichie	WB	118	124	6
Clay		124	140	16
Calichie	WB	140	144	4
Clay		144	152	8
Calichie	WB	152	154	2
Clay		154	157	3
Calichie	WB	157	160	3

Date started February 27, 1995
Date completed 3-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
APR 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8" x 1 3/8"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 4-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627