WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47492
Permit No.
Basin 162

NOTICE OF INTENT NO. 14581

1. OWNER Glen Shepherd
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 28 Game bird

2. LOCATION SW ¼ SW ¼ Sec. 35 T 20S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 41-181-15 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	18	14
Calichie		18	21	3
Clay		21	29	8
Calichie		29	32	3
Clay		32	44	12
Calichie		44	46	2
Clay		46	54	8
Calichie	WB	54	57	3
Clay		57	65	8
Calichie	WB	65	67	2
Clay		67	70	3
Calichie	WB	70	72	2
Clay		72	93	21
Calichie	WB	93	95	2
Clay		95	108	13
Calichie	WB	108	111	3
Clay		111	118	7
Calichie	WB	118	121	3
Clay		121	137	16
Calichie	WB	137	139	2
Clay		139	155	16
Calichie	WB	155	160	5

RECEIVED APR 14 1995 Div. of Water Resources Branch Office Las Vegas, NV

Date started 2-27, 1995
Date completed 3-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	160

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCK 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 4/10/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627