WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47423
Permit No.
Basin

NOTICE OF INTENT NO. 14579

1. OWNER KLH Const
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 14 Pahrump Valley BLVD.

2. LOCATION NE ¼ SE ¼ Sec 34 T 20S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-694-06 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	14	9
Calichie		14	16	2
Clay		16	23	7
Calichie		23	25	2
Clay		25	42	17
Calichie		42	45	3
Clay		45	53	8
Calichie	WB	53	56	3
Clay		56	68	12
Calichie	WB	68	70	2
Clay		70	77	7
Calichie	WB	77	79	2
Clay		79	88	9
Calichie	WB	88	94	6
Clay		94	106	12
Calichie	WB	106	115	9
Clay		115	119	4
Calichie	WB	119	122	3
Clay		122	133	10
Calichie	WB	133	135	2
Clay		135	140	5

RECEIVED
APR 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-27, 1995
Date completed 3-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	16.94	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30886
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun
(By driller performing actual drilling on site or contractor)
Date 4/10/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627