WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47474
Permit No.
Basin

NOTICE OF INTENT NO. 14584

1. OWNER Real Estate Unlimited
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3230 W. Flamingo

2. LOCATION SE ¼ SE ¼ Sec. 23 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-823-23 (Parcel No.) Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	17	13
Calichie		17	20	3
Clay		20	28	8
Calichie		28	31	3
Clay		31	54	23
Calichie	WB	54	57	3
Clay		57	71	14
Calichie	WB	71	74	3
Clay		74	85	11
Calichie	WB	85	88	3
Clay		88	101	13
Calichie	WB	101	106	5
Clay		106	114	8
Calichie	WB	114	120	6
Clay		120	130	10
Calichie	WB	130	135	5
Clay		135	140	5

RECEIVED
APR 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 6, 19 95
Date completed March 9, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 0 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dn (By driller performing actual drilling on site or contractor)
Date 4/10/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627