

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 17494
 Permit No. 29226-T
 Basin

NOTICE OF INTENT NO. 13201

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Las Vegas Valley Water Dist. ADDRESS AT WELL LOCATION SE Corner of Vegas Drive and Cimarron Rd.
 MAILING ADDRESS 1001 Valley View Las Vegas, Nevada 89153
 2. LOCATION NE 1/4 NW 1/4 Sec. 28 T 20 N/S R 60 E Clark County
 PERMIT NO. 59826T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
NOT LOGGED		0	100	
Rock & gravel		100	150	
Rock, sand & gravel		150	160	
Gravel and rock		160	180	
Sand, gravel & rock		180	190	
Sand and gravel		190	200	
Gravel and Rock		200	250	
Sand and Gravel		250	260	
Gravel and Rock		260	300	
Sand and Gravel		300	340	
Gravel and Rock		340	390	
Sand, Gravel w/Rock		390	410	
Silty sand/some small rock		410	450	
sand, gravel mix (fine)		450	460	
Silty sand/small pebbles		460	480	
Silty sand, some gravel		480	500	
Silty sand/some rock		500	560	
Silty sand		560	580	
Silty sand/Gravel		580	650	
Sand, some silt		650	670	
Silt, sand, gravel particles		670	690	
Silty sand		690	740	
Fine sand		740	790	
Fine sand, some silt		790	800	
Silty sand		800	900	
Silty sand and clay		900	930	
Sand, shale stringers		930	950	
Sand and Shale		950	1100	
Sand, stringers of shale		1100	1120	

8. WELL CONSTRUCTION
 Depth Drilled 1160 Feet Depth Cased 1140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 34 Inches To 0 Feet 1160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24"	97	.375	0	600
			740	760
			840	860

Perforations: Copper and: 1120 to 1140
 Type perforation wire wrapped
 Size perforation 100"
 From 600 feet to 740 feet
 From 760 feet to 840 feet
 From 860 feet to 1120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100 ft.
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 1160 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BEYLIK DRILLING, INC.
 Address 555 S. Harbor Blvd. La Habra, California 90631
 Nevada contractor's license number 0007055A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
 Signed [Signature] for: Beylik Drilling
 By driller performing actual drilling on site or contractor
 Date Oct. 17, 1994

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Lift
 Static 511 ft. P.M. 2500 Draw Down (Feet Below Static) 89 ft. Time (Hours) 24
 Date started Aug. 24, 1994
 Date completed October, 1994
 STATE ENGINEER
 Div. of Water Resources
 Branch Office - Las Vegas

RECEIVED
 MAY 03 1995
 STATE ENGINEER

