REPORT NO. 95.08

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 47489
PERMIT NO.
BASIN 1005

NOTICE OF INTENT NO. 28507

1. OWNER Phillip Priewe
MAILING ADDRESS Box 60176 Reno, Nv 89506

ADDRESS OF WELL 20005 US Hwy 395 Noth
Reno, Nv 89506

2. WELL LOCATION NW 1/4 NW 1/4 SEC. 29 T 21N R 18 E Washoe COUNTY

PERMIT NO. PARCEL NO 081-210-01 SUBDIVISION NAME Northridge

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Green, red & brown sands & gravels		0	164	164
Sticky brown clay w/smal sands &		164		
gravel zone		164	180	16

Notes :

Date Started 2/8/95 Date Completed 2/15/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	20		3

8. WELL CONSTRUCTION

Depth Drilled 180 Depth Cased 180

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 62 Feet
8 1/2 Inches 62 Feet 180 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1.5	180

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 140 Feet to 160 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 60'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 60 Feet to 180 Feet

9. WATER LEVEL
Static Water Level 65 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1511

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated 2/16/95