

OFFICE USE ONLY  
 Log No. 47491  
 Permit No. \_\_\_\_\_  
 Basin 092B

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22862

1. OWNER GORDON & DEANNA WAUGH ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 11015 Deodar \_\_\_\_\_  
Reno, Nevada 89506 \_\_\_\_\_  
 2. LOCATION SW 1/4 SE 1/4 Sec. 23 T. 21N N/S R. 19 E Washoe \_\_\_\_\_  
 PERMIT NO. 080-263-08 \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name Lemmon Valley

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other Clean \_\_\_\_\_  
 Municipal/Industrial  Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
PUMP LODGED IN WELL				
11-16-94				
Weld square on pitless				
Rig up - change bit				
Drill up black plastic pipe				
Trip out of hole - change bit - drill up pump and granite rocks, and pump wire. No rope found				
Trip out- change bit.				
Evaluate well:				
Static water level at <u>71</u> feet				
Approximate <u>8 - 9</u> GPM				
Total depth of well <u>134</u> feet				
WELL DEEPENING:				
11-21-94				
Brown clay		134	137	3
Granite sands	X	137	161	24
Brown clay		161	165	4
Granite sands, coarse	X	165	174	9
Brown clay		174	177	3

8. WELL CONSTRUCTION  
 Depth Drilled 177 Feet Depth Cased 177 Feet

HOLE DIAMETER (BIT SIZE)  
 From 134 Feet To 177 Feet  
6 1/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	177

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 112 feet to 172 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 130 feet to 177 feet

9. WATER LEVEL  
 Static water level 71 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date November 22, 1994

Date started 11-16-94, 19\_\_\_\_  
 Date completed 11-21-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		