REPORT NO. 95.04

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 47496
PERMIT NO.
BASIN 085

NOTICE OF INTENT NO. 25506

OWNER Paul Neuffer
MAILING ADDRESS 980 Caughlin Crossing Reno, Nv 89509

ADDRESS OF WELL 765 Friedman Cr
Sparks, Nv 89436

2. WELL LOCATION NW 1/4 NW 1/4 SEC. 18 T 21N R 21 E Washoe COUNTY

PERMIT NO. PARCEL NO 76-360-43 SUBDIVISION NAME Spanish Springs

3. TYPE OF WORK

[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE

[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE

[ ] Cable [X] Rotary [ ] PVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Tan, brown & white DG		0	58	58
Fractured, green white & brown DG		58	615	557

Notes :

Date Started 1/19/95 Date Completed 1/27/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	20+		4

8. WELL CONSTRUCTION

Depth Drilled 615 Depth Cased 615

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 62 Feet
8 1/2 Inches 62 Feet 615 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.96	.188	+2	615

PERFORATIONS:

Type Perforation factory Size Perforation 3/32 x 3
From 595 Feet to 615 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 120'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 120 Feet to 615 Feet

9. WATER LEVEL

Static Water Level 500 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1511

Signed [signature]
By driller performing actual drilling on site or contractor

Dated 1/30/95