WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 23 above

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47499
Permit No.
Basin 093

NOTICE OF INTENT NO. 22870

1. OWNER TERRY CLARK
MAILING ADDRESS 1398 Antelope Valley Road
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SE ¼ Sec. 23 T. 22N N/S R. 19E E. Washoe County
PERMIT NO. Issued by Water Resources 079-470-~~27~~ 92 Parcel No. Antelope Valley Rock Estates Subdivision Name #1980 part 3

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Soft Brown Sand		1	4	3
Brown Sandy Clay		4	16	12
Green Corase Granite Sands		16	26	10
Brown Sandy Clay		26	68	42
Fire Brown Sand		68	73	5
Brown Sandy Clay		73	116	43
Med Sand Brown	x	116	141	25
Soft Sandy Clay		141	145	4

Date started January 17, 1995, 19
Date completed January 19, 1995, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	145 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	145

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
Address P.O. Box 12370 Contractor
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date January 25, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627