

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29543

1. OWNER Paul Caria ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 4705 Axehandle Rd.
Reno, NV 89510
 2. LOCATION NW 1/4 NE 1/4 Sec. 32 T. 22N N/S R. 21E E Washoe County
 PERMIT NO. 076-180-21 Parcel No. 32-2-63 Palomino Valley Unit 4 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
D.G.		1	4	3
Weathered Granite		4	8	4
Hard Gray Granite		8	30	22
Weathered Granite (soft)		30	33	3
Hard Gray Granite		33	71	38
soft zone (D.G)		71	72	1
Hard Gray Granite		72	93	20
soft zone (Rusty Weathered Granite) (No Water)		93	95	2
Hard Gray Granite		95	156	61
Soft Zone		156	157	1
Hard Gray Granite		157	206	49
Fracture Rock (Green to Black)		206	212	6
Dark Gray & Green Granite		212	236	24
Softer Drilling				
Gray Granites		236	412	176
Gray Med Hard Granite with streaks of little soft zone.		412	559	147
Fracture (app. 1-2 GPM) X		559	560	1
Gray Granite		560	585	25
Fracture Black Volcanic				
Rock (10GPM) X		585	624	39
Gray Granite		624	644	20
Fracture Rock (3GPM) X		644	664	20
Gray Granite		664	678	14

8. WELL CONSTRUCTION
 Depth Drilled 678 Feet Depth Cased 678 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 50 Feet
 10 Inches
 8 5/8 Inches 50 Feet 678 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	678

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 534 feet to 554 feet
 From 613 feet to 673 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Depth of Seal 50 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 678 feet

9. WATER LEVEL
 Static water level 481 feet below land surface
 Artesian flow _____ G.P.M. 16 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling Inc. driller performing actual drilling on site or contractor
 Date February 17, 1995

Requested by log # B1296
 Date started 2/6/95 19____
 Date completed 2/14/95 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>16</u>		