

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER: PAT HALL ADDRESS AT WELL LOCATION: Theodore
 MAILING ADDRESS: 316 SEMMOR DR JANECRADO MINO VALLEY
191 RENO, NEV 89506
 2. LOCATION: 17650 N. N.W. 1/4 Sec 6 23 T. 23 N. N/S R 20 E E County
 PERMIT NO. 005211 Parcel No. 07620005 Subdivision Name 17650 Renogark Blvd Reno, Nev 89506

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE: Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	30	
SAND		30	40	
CLAY		40	60	
GRAY CLAY & STREAKS		60	100	
OLIVE CLAY				
RED CLAY		100	135	
Red clay & VEC Rock		135	200	

8. WELL CONSTRUCTION
 Depth Drilled: 300 Feet Depth Cased: 220 Feet
 HOLE DIAMETER (BIT SIZE)
 12" From 0 Feet To 50 Feet
 8" Inches 50 Feet To 200 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 1/2"			0	180

Perforations:
 Type perforation: FACTORY
 Size perforation: 1 1/2"
 From 190 feet to 200 feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 50 FT
 Placement Method: Pumped Poured
 Gravel Packed: Yes No

9. WATER LEVEL
 Static water level: _____ feet below land surface
 Artesian flow: 59 AIS G.P.M. _____ P.S.I.
 Water temperature: 102 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: ED MILLER Contractor
 Address: 200 ARTIST VIEW Contractor
WELLINGTON, NV 89444
 Nevada contractor's license number 32166 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 786
 Signed: Ray Nigginbhatam
 Date: JAN 6 - 95

Date started: OCT 25 - 1994
 Date completed: JAN 6 - 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25 GALS per</u>	<u>MIN.</u>	