

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27393

1. OWNER Ouida Oil, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2201 Midway Road _____
Carrolton, Texas 75006 _____
 ADDRESS Dixie Valley Nevada _____

2. LOCATION NW 1/4 NE 1/4 Sec 25 T 25 N/S R 37 E Pershing County
 PERMIT NO. OG-176 743 API# 27-027-05003 APD# 41325
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay		2	10	8
Gravel		10	18	8
Brwon Clay		18	30	12
Gravel		30	35	5
Brwon Clay		35	52	17
Sand & Gravel		52	60	8
Brown Clay		60	75	15
Gravel		75	90	15
Brown Clay		90	97	7
Sand & Gravel		97	110	13
Brown Clay		110	135	25
Gravel		135	185	50
Brown Clay		185	190	5
Gravel	XX	190	285	95
Clay		285	289	4
Gravel	XX	289	345	56

8. WELL CONSTRUCTION
 Depth Drilled 345 Feet Depth Cased 345 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 345
12 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.94	.188	0	345

Perforations:
 Type perforation Mill-Cut
 Size perforation 1/8"
 From 200 feet to 345 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 150 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 345 feet

Date started November 22 1994
 Date completed November 30 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PARSONS DRILLING, INC. Contractor
 Address P.O. BOX 1265 Contractor
FALLON, NEVADA 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Peay
 By driller performing actual drilling on site or contractor
 Date December 19, 1994