XX Well #2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47520
Permit No. MO-853
Basin 054

I

NOTICE OF INTENT NO. 19958

1. OWNER Al Park Petro
MAILING ADDRESS PO Box 2877
Elko, Nev 89803

ADDRESS AT WELL LOCATION Crescent Valley Store
25 miles NE ST HWY 306
Crescent Valley

2. LOCATION NW ¼ SW ¼ Sec. 5 T. 29 N/S R. 48 E. Eureka County

PERMIT NO. MO-853 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel w/ Cobbles		0	19	
Clayey-Gravel		19	24.5	
Silty Clay w/		24.5	27	
Clayey - Gravel		27	49	
Silty Clay, Gravel		49	52	
Clayey - Gravel		52	67	
Silty Clay		67	75	
Sandy, Clayey Gravel		75	80	
" " "		80	50	

Flush mnt Protector
Schedule 0
2'
Cement
Bentonite 22
25
30
1/4 Pea Gravel
040 Screen
50
55'
Bentonite
77
80
10/20 Sand
020 Screen
90

Date started 1/4, 1995
Date completed 1/19, 1995

JAN 23 P12:19

7. WELL TEST DATA

TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	dry in	7 trys.	Water at 87'.
Recovery	real slow.		

8. WELL CONSTRUCTION
Depth Drilled 90' Feet Depth Cased 90' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0 Feet	90 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	30'
4"		SCH 40	50'	80'
4"		SCH 40		

Perforations:
Type perforation Factory Slot
Size perforation 020, 040
From 30' feet to 50' 040 feet
From 80' feet to 90' 020 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 22'
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 25' feet to 55' 1/4 Gravel feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout
77' to 90' 10/20 sand

9. WATER LEVEL
Static water level 87' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name P C Exploration Inc
Contractor
Address 1125 W 650 No
Contractor
Centerville, Ut 84014

Nevada contractor's license number issued by the State Contractor's Board 95-7301

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1605

Signed Ray Fraser
By driller performing actual drilling on site or contractor
Date 1-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627