


XX

#3

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 47521  
Permit No. \_\_\_\_\_  
Basin 054



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1988  
Crescent Valley State

1. OWNER Al Park Petro ADDRESS AT WELL LOCATION Crescent Valley State  
MAILING ADDRESS PO Box 2877 25 miles NE St Hwy 306  
Elko, Nev 85803 Crescent Valley  
2. LOCATION NW 1/4 S 29W 1/4 Sec. 5 T. 29 N. R. 48 E. Paria County  
PERMIT NO. MO-853 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Gravel w/ cobbles		0	21	
Sandy Clayey Gravel		21	30	
Sandy Clay		30	34	
Sandy Clayey Gravel		34	50	
Sandy Clayey Gravel w/ cobbles		50	61	
Silty Clay - moist		61	65	
Clayey Gravel		65	100	
Sandy Clay	102	100	105	
Sandy Clayey Gravel		105	112	
" " "		112	115	

Flush Mant Protector - 2' section  
Cement Grout  
95' Bentonite  
98'  
100'  
110'  
115'

JAN 23 11:19 AM  
102' Seal  
020' Screen

8. WELL CONSTRUCTION  
Depth Drilled 115 Feet Depth Cased 110 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
8 Inches 0 Feet 115 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>SCH 40</u>	<u>0</u>	<u>100</u>

Perforations:  
Type perforation Factory slot  
Size perforation 020  
From 100' feet to 110 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 5.9'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
95' to 98' Bentonite  
Gravel Packed:  Yes  No  
From 98' feet to 115' 1020 sand

9. WATER LEVEL  
Static water level 102' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 05/14/95, 1995  
Date completed 1/19/95, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1</u>	<u>6'</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name P.C. Exploration Inc Contractor  
Address 1125 West 650 N 0 Contractor  
Centerville, Ut 84014  
Nevada contractor's license number issued by the State Contractor's Board 95-7301  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1605  
Signed Ray Fraser  
By driller performing actual drilling on site or contractor  
Date 1-20-95