



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19958

1. OWNER Al Park Petro ADDRESS AT WELL LOCATION Crescent Valley Store
MAILING ADDRESS PO Box 2877 25 miles NE HWY 306, Crescent Valley
Elko, Nev 85803 Evans County
2. LOCATION NW 1/4 SW 1/4 Sec 8 T 29 R 48 E
PERMIT NO. MO-852 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Gravel w/silt		0	20	
Silty Clayey Gravel		20	26	
Clayey Silt		26	28	
Sandy Silty Gravel		28	53	
Clay		53	54.5	
Sandy Gravel w/cobbles		54.5	58	
Silty Sand		58	60	
Sandy Clayey Gravel		60	76	
Clayey Gravel w/sand		76	83	
Gravelly Sandy Clay		83	85	
Sandy Gravel		85	87	
Sandy Gravelly Clay		87	105	

Handwritten notes and diagrams:
- 1/4" screen at 20'
- 3/4" screen at 32'
- Bentonite at 35'
- 1/4" screen at 42'
- 3/4" screen at 62'
- Bentonite at 63'
- 1/2" screen at 82'
- 1/2" screen at 102'
- 18' Sand
- Bentonite at 20'

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
8" Inches 0 Feet 105 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40	0	22
4"		Sch 40	32	42
4"		Sch 40	62	82

Perforations:
Type perforation Factory slot
Size perforation 0.20 - 0.40

From 22 feet to 32 0.20 feet
From 42 feet to 62 0.40 feet
From 82 feet to 102 0.40 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal Cement Grout - subside Neat Cement
Placement Method: Pumped Cement Grout
 Poured 82'-102' 1/2" sub Concrete Grout
Gravel Packed: Yes No
From 20' 0.42 feet to 35' 0.62 1/2" Gravel feet

9. WATER LEVEL
Static water level 99' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 12/4/1985
Date completed 1/19/1985

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PC Exploration Inc Contractor
Address 1125 W 650 NO Contractor
Centerville, UT 84014

Nevada contractor's license number issued by the State Contractor's Board 95-7301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1605

Signed Ron Trusser
By driller performing actual drilling on site or contractor
Date 1-21-85