



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 25117

1. OWNER Shirley Wells ADDRESS, AT, WELL LOCATION 3555  
MAILING ADDRESS 3555 Hillsboro Hillsboro Fallon, Nev.  
FALLON NEV  
2. LOCATION SW 1/4 SE 1/4 Sec 9 T. 19 N. R. 28 E. Churchill County  
PERMIT NO. 008-052-49 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock  Other

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

| Material      | Water Strata | From | To  | Thick-ness |
|---------------|--------------|------|-----|------------|
| SAND          |              | 0'   | 1'  | 1'         |
| CLAY          |              | 1'   | 2'  | 1'         |
| SAND          |              | 2'   | 8'  | 6'         |
| CLAY          |              | 8'   | 10' | 2'         |
| SILT          |              | 10'  | 14' | 4'         |
| CLAY          |              | 14'  | 24' | 10'        |
| SAND          |              | 24'  | 30' | 6'         |
| CLAY          |              | 30'  | 52' | 22'        |
| SAND + GRAVEL | ✓            | 52'  | 57' | 5'         |
| CLAY          |              | 57'  |     |            |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 57 feet

Casing record  
Weight per foot 13.77 Thickness 1.88

| Diameter         | From          | To             |
|------------------|---------------|----------------|
| <u>10</u> inches | <u>0</u> feet | <u>50</u> feet |
| <u>6</u> inches  | <u>0</u> feet | <u>57</u> feet |

Surface seal: Yes  No  Type Grout  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
Type perforation Machined  
Size perforation 1/4 x 3  
From 52 feet to 57 feet

Date started Dec 2, 19 94  
Date completed Dec 6, 19 94

7. WELL TEST DATA

| Pump RPM    | G.P.M.    | Draw Down   | After Hours Pump |
|-------------|-----------|-------------|------------------|
| <u>3450</u> | <u>16</u> | <u>2 ft</u> | <u>4</u>         |

9. WATER LEVEL  
Static water level 10 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name VERNON CANNON Contractor  
Address 4555 Hwy 50W. Silver Springs Contractor  
Nevada contractor's license number issued by the State Contractor's Board 23317  
Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455  
Signed Vernon Cannon By driller performing actual drilling on site or contractor  
Date Dec 10, 1994

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours