

OFFICE USE ONLY
 Log No. 47540
 Permit No. _____
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Ruth Ogden ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 150 N. ByBee Lane
Yerington, Nev 89449
 2. LOCATION SW 1/4 NW 1/4 Sec 23 T 14 N R 26 E Lyon County
 PERMIT NO. 14-231-03
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Place neat cement from bottom to top				
19 Bags Pump 30-40 gal water flow OVER top				
Par Telephone call to Matt Dillon on 9-7-94 @ 3:20 OK to pump neat cement only				
Well IN Bad Shape				
Sand in water				
IRON				
Salty Taste				

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>-</u>	<u>.156</u>	<u>+1</u>	<u>69</u>

Perforations:
 Type perforation Sawed or Touch
 Size perforation 3/32 x 3 x 6 Rows
 From 50 feet to 20 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 20 feet

Date started 9-4-94, 19 94
 Date completed 10-4, 19 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
(Table content is crossed out with a large X)			

9. WATER LEVEL
 Static water level 23 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality POOR TO FAIR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. ByBee Lane Contractor
Yerington Nev 89449
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed R. Ogden
 By driller performing actual drilling on site or contractor
 Date 11-22-94

Log No. 47540
Permit No. 108
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER Ruth Ogden ADDRESS AT WELL LOCATION 150 N. ByBee Ln. Yerington Nev 89442
MAILING ADDRESS 150 N. ByBee Lane Yerington Nev 89442
2. LOCATION SW 1/4 NW 1/4 Sec 23 T 14 R 26E E Lyon County
PERMIT NO. 14-331-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	3	3
Fine To Coarse Sand		3	10	7
Bluish Gray Clay -				
Fine Sand		10	18	8
Fine To Coarse Sand		18	20	2
Brown Clay		20	21	1
Fine To Coarse Sand		21	30	9
Brown Clay - Coarse				
Sand - Small Gravel		30	36	6
Coarse Sand - Small				
Gravel		36	45	9
Small Gravel -				
Brown Clay		45	48	3
Brown Clay		48	55	7
Brown Clay - Sand		55	94	39
Brown Clay - Small				
Gravel		94	112	18
Fine To Coarse Sand -				
Clay Stratas		112	116	4
Coarse Sand -				
Gravel		116	128	12
Coarse Sand - Gravel -				
Clay Stratas		128	133	5
Coarse Sand - Small				
Gravel		133	135	2
Brown Clay		135	140	5
Fine To Coarse Sand -				
Clay Stratas		140	162	22

See Page #2

8. WELL CONSTRUCTION
Depth Drilled 279 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 279 Feet
6 3/8 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>71</u>	<u>279</u>

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" 6 Rows
From 259 feet to 279 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
From 50 feet to 279 feet

Date started 9-7 1994
Date completed 9-13 1994


7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>25</u>	<u>10</u>	<u>1/2 HR</u>
<u>AIR LIFT</u>	<u>100</u>	<u>100' air line</u>	<u>3 HRS</u>

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling Contractor
Address 162 N ByBee Lane Yerington Nev 89442 Contractor
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden By driller performing actual drilling on site or contractor
Date 11-27-94



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 108

NOTICE OF INTENT NO. _____

1. OWNER Ruth Ogden ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 150 N. By Bee Lane
Yerington Nev 89447
 2. LOCATION SW 1/4 NW 1/4 Sec. 23 T. 14 R. 26 E. Lyon County
 PERMIT NO. 14-331-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

#2

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bluish Gray Clay		162	164	2
Brown Clay		164	166	2
Coarse Sand-Gravel		166	176	10
Brown Clay-Sand		176	195	19
Bluish Gray Clay		195	200	5
Brown Clay		200	206	6
Fine To Coarse Sand		206	215	9
Coarse Sand-Small Gravel		215	225	10
Brown Clay-Gravel		225	228	3
Coarse Sand-Small Gravel-Clay		228	231	3
Clay-Gravel		231	245	14
Bluish Gray Clay-Gravel		245	248	3
Coarse Sand-Gravel-Few Rock	X	248	279	31

8. WELL CONSTRUCTION
 Depth Drilled 279 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 279 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>279</u>

Perforations:
 Type perforation Sawed
 Size perforation 3 1/2 x 3" 6 Rows
 From 257 feet to 279 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 279 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

Date started 9-7, 1994
 Date completed 9-13, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>25</u>	<u>10</u>	<u>1/2 HR</u>
<u>AIR LIFT</u>	<u>100</u>	<u>100' air line</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. By Bee Lane Contractor
Yerington NV
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed R. Ogden
 By driller performing actual drilling on site or contractor
 Date 11-27-94