WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47551
Permit No.
Basin 059

NOTICE OF INTENT NO. 20169

1. OWNER U-SERVE STATION
MAILING ADDRESS 292 E. FRONT ST. BATTLE MOUNTAIN, NV.
ADDRESS AT WELL LOCATION SAME

2. LOCATION NE ¼ NW ¼ Sec. 20 T. 32 N/S R. 45 E. LANDER County
PERMIT NO. M/O 662 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG #3

Material	Water Strata	From	To	Thickness
ON THE SIXTH				
OF OCTOBER, I				
FOUND THE THE				
MONITORING WELL				
TO BE IN GOOD				
CONDITION. AFTER				
REMOVING THE LID				
I BAILED THE				
CASING OUT				
FROM 0 TO 20				
FEET. AFTER				
DRILLING THE				
CASING OUT				
I PRESSURE GROUTED				
THE WHOLE WITH				
CEMENT FROM				
20 TO 0 FEET.				

Date started 10/6, 1994
Date completed 10/6, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 20' FT Feet Depth Cased 20' FT Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0' Feet	20' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	40	PVC	0'	20'

Perforations:
Type perforation FACTORY
Size perforation .020
From 5' feet to 15' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling (Contractor)
Address 1635 Belford Rd. Reno, NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 12/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627