

OFFICE USE ONLY
 Log No. 47555
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29093

1. OWNER Tim + Cilly Peacock ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 3680 6200 VAN DIEST ROAD
WINNEMUCA, NV 89445 WINNEMUCA, NV 89445
 2. LOCATION NE 1/4 SW 1/4 Sec 6 T 33 N 35 E Prushing County
 PERMIT NO. _____
 Issued by Water Resources 9-300-62 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>80% Clay 20% Sand</u>		<u>0</u>	<u>20</u>	
<u>and Gravel</u>				
<u>14 inches out of clay</u>		<u>20</u>	<u>100</u>	
<u>layers of 33% clay</u>				
<u>33% sand 33% gravel</u>				

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1.188</u>	<u>1</u>	<u>100</u>

Perforations:
 Type perforation Factory Sme Cut
 Size perforation 3/32
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 32 feet below land surface
 Artesian flow No Pressure G.P.M. NO P.S.I.
 Water temperature 60 °F Quality Good

Date started 11-9, 1994
 Date completed 11-14, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>	<u>UNKNOWN</u>	<u>4 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Contractor
 Address 10760 Grass Valley Road
WINNEMUCA, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 024167
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 01-16-95