WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. U7557
Permit No.
Basin 060

NOTICE OF INTENT NO. 28654

1. OWNER Mine Service & Supply Co.
MAILING ADDRESS PO Box 340
Battle Mountain,NV 89820

ADDRESS AT WELL LOCATION Mine Service & Supply
Dunphy, NV

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 33 (N) R. 48 E. Eureka County
PERMIT NO. MO-891 (Issued by Water Resources) | Unknown (Parcel No.) | N/A (Subdivision Name) | B-2

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	3	3
Fine Silt,light brown		3	5	2
Large gravels		5	8	3
Gravel/Sand	9	8	18	10

Date started 1/4, 19 95
Date completed 1/4, 19 95

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed water from hole		
approximately 5 well volumes		

8. WELL CONSTRUCTION
Depth Drilled 18 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	18 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8	PVC	SCH 40	0	8

Perforations:
Type perforation Slotted/Factory
Size perforation .010
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 6'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Bentonite Pellets
Gravel Packed: [X] Yes [ ] No
From 6 feet to 18 feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow N/A G.P.M. ---- P.S.I.
Water temperature -- °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boyles Bros. Drilling Co. (Contractor)
Address 4490 W 1707 S SLC, UT 84125 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5830
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1883
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/10/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627