WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47569
Permit No.
Basin 045

NOTICE OF INTENT NO.

1. OWNER William Eldridge
MAILING ADDRESS 290-5 P.V. Estates
ADDRESS AT WELL LOCATION None

2. LOCATION S W ¼ N W ¼ Sec. 26 T. 33 N/S R. 57 E. Elko County
PERMIT NO. (Issued by Water Resources) Lot 7, Blk D (Parcel No.) ~~[illegible]~~ Pleasant Valley Est. (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, sand, gravel & boulders		0	98	98
Sand (poor qual.	✓	98	108	10
Clay, sand, gravel & boulders		108	182	74
Sand & gravel in streaks w/clay	✓	182	208	26
Clay		208	215	7
T.D. 215				

Date started 12-13, 1994
Date completed 12-22, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	20	2 hrs.
40	45	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	108 Feet
6 Inches	108 Feet	215 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.0	215'

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 4
From feet to feet
From 170 feet to 209 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to T.D. feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Muth Drilling Co.
Address (Contractor) 203 Pine St.
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth
(By driller performing actual drilling on site or contractor)
Date 12-27-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627