

OFFICE USE ONLY
 Log No. 42575
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28099

1. OWNER Humboldt Realty Pam Fabor ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 1665 270 McNeil St
Winnemucca, NV 89445 Winnemucca, NV 89445
 2. LOCATION NW 1/4 SE 1/4 Sec 4 T 34 N/S R 37 E Humboldt Pershing County
 PERMIT NO. Domestic 09-031-09 Lot 9 Rose Peak Farms
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>70% Clay 30% Sand</u>		<u>0</u>	<u>10</u>	
<u>75% Red Clay 25% Sand</u>		<u>10</u>	<u>80</u>	
<u>30% Red Clay 70% Sand</u>				
<u>and Gravel</u>	<u>XX</u>	<u>80</u>	<u>100</u>	

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 100
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>1.88</u>	<u>1</u>	<u>100</u>

Perforations:
 Type perforation Factory Saw Cuts
 Size perforation 3/32
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 100 feet

Date started 1-24, 1995
 Date completed 1-25, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>unknown</u>	<u>4 hrs</u>

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow NO G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 Grass Valley Rd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 024167
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
 Signed [Signature]
 by driller performing actual drilling on site or contractor
 Date 1-27-95