WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47601 in Book
Permit No.
Basin 212

NOTICE OF INTENT NO. 13721

1. OWNER: DAVE DURANT
MAILING ADDRESS:
ADDRESS AT WELL LOCATION: HWY 160 + SEELIGER

2. LOCATION: NE ¼ NW ¼ Sec. 29 T. 22 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources): 176-29-101 (Parcel No.) Subdivision Name:

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY + GRAVEL | | 0 | 50 | 50 |
| SANDSTONE | 415 | 50 | 460 | 410 |
| LIMESTONE | | 460 | 600 | 140 |

RECEIVED
MAY 15 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started: 4-21, 1995
Date completed: 4-26, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12¼ Inches | | 0 Feet | 60 Feet |
| 9⅞ Inches | | 60 Feet | 600 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6⅝ | 12.92 | .188 | +1 | 600 |

Perforations:
Type perforation: FACTORY SAW.
Size perforation: 1/8 x 2 1/2
From 560 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal: 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 600 feet

9. WATER LEVEL
Static water level: 366 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: °F Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): DESERT DRILLING
Address (Contractor): 6475 GARY AVE
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board: 34274
Nevada driller's license number issued by the Division of Water Resources, the onsite driller: 1966
Signed: Randall Cook
By driller performing actual drilling on site or contractor
Date: 5-6-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627