2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47608
Permit No.
Basin 161

NOTICE OF INTENT NO. 14097

1. OWNER John Edwards
MAILING ADDRESS 236 Chasan St
Las Vegas NV 89017

ADDRESS AT WELL LOCATION Same Address
Gold Crest NV

2. LOCATION NE ¼ SE ¼ Sec. 36 T. 17 N/S R. 55 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 540-540-005 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Clay		0	5	5
Cemented Gravel		5	55	50
Sandstone Yellow		50	65	15
Red Sand Stone		65	85	20
Gray Granit		85	150	65
Loose Gravel		150	175	25
Fracture open Earth		175	185	10
Limy Stone	188	185	190	5

RECEIVED
MAY 31 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-1, 1994
Date completed 5-, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	70	1
2	30	2
1	10	3
½	5	4

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8½ Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	20	.255	0	190

Perforations:
Type perforation Factory
Size perforation 1/16 x 4"
From 120 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce Robinson (Contractor)
Address PO Box 302 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 15972
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
Signed Bruce Robinson (By driller performing actual drilling on site or contractor)
Date 5-23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627