WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49617
Permit No.
Basin 162

NOTICE OF INTENT NO 21986

1. OWNER Eugene Mayea
MAILING ADDRESS PO BOX 632 ~~Pahrump~~ Pahrump NV 89041
ADDRESS AT WELL LOCATION 1280 E Camelback

2. LOCATION SW ¼ SW ¼ Sec 35 T 20S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 41-181-19 (Parcel No.) Calnada Unit 7 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	4'	4'
Sandstone		4	8	4
Sticky Clay		8	10	2
Soft Limestone		10	25	15
Sticky Clay		25	28	3
White Hard Caliche		28	40	12
Lt Br Clay		40	50	10
Hard pan		50	55	5
Brown Clay		55	60	5
Sticky Br Clay		60	65	5
Grey Clay		65	70	5
Brown Clay		70	80	10
Soft Clay		80	84	4
Firm Br Clay		84	110	24
Sandstone		110	112	2
Lt Br Clay		112	125	13
Sand		125	128	3
Soft Clay		128	140	12

RECEIVED
MAY 22 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4/30, 1995
Date completed 5/10, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	10	4 min

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18	188	0	140

Perforations:
Type perforation 20' Factory
Size perforation 1/8 X 3
From 125 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 55 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eugene Mayea (Contractor)
Address PO BX 632 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035506
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1864
Signed X Eugene Mayea (By driller performing actual drilling on site or contractor)
Date 5/10/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627