

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14709

1. OWNER Robert Smith ADDRESS AT WELL LOCATION 2851 E. Desert Hills Circle
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NE 1/4 Sec. 36 T. 21-S N/S R. 53 E. Nye County Nye
 PERMIT NO. 29-191-05 Desert Hills, Blk 1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---------------------|--------------|------|-----|-----------|
| Surface | | 0 | 4 | 4 |
| Sandy loam | | 4 | 8 | 4 |
| Brown clay/caliche | | 8 | 36 | 28 |
| Limestone | | 36 | 40 | 4 |
| Brown clay/caliche | | 40 | 74 | 34 |
| Brown clay | | 74 | 96 | 22 |
| Brown clay/caliche | | 96 | 108 | 12 |
| Brown clay | X | 108 | 126 | 18 |
| Brown clay/caliche/ | | 126 | 144 | 18 |
| Sandstone | | | | |
| Brown clay | X | 144 | 172 | 28 |
| Brown clay/caliche/ | X | 172 | 190 | 18 |
| Sandstone | | | | |
| Brown clay | | 190 | 200 | 10 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8 | 16.94 | .188 | 0 | 200 |
| | | | | |
| | | | | |

Perforations:
 Type perforation Torch Cut
 Size perforation 1" width 8" long
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 94 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number 17563A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1812
 Division of Water Resources, the on-site driller.
 Signed Will A. [Signature]
 By driller performing actual drilling on site or contractor
 Date May 11, 1995

Date started May 10, 1995
 Date completed May 10, 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>20</u> | <u>4</u> | <u>1/2</u> |
| | | | |
| | | | |
| | | | |
| | | | |

RECEIVED
 MAY 22 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV