

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 16151

1. OWNER Steve Barnes ADDRESS AT WELL LOCATION 4610 Whirlwind
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 1 T. 21 S. N/S R. 53 E. Nye County
 PERMIT NO. 44-092-19 Manco Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	2	2
Caliche		2	4	2
Clay		4	13	9
Caliche		13	15	2
Clay		15	21	6
Caliche		21	24	3
Clay		24	29	5
Caliche		29	32	3
Clay		32	41	9
Caliche		41	43	2
Clay		43	52	9
Caliche	WB	52	55	3
Clay		55	66	11
Caliche	WB	66	69	3
Clay		69	79	10
Caliche	WB	79	83	4
Clay		83	107	24
Caliche	WB	107	112	5
Clay		112	121	9
Caliche	WB	121	124	3
Clay		124	137	13
Caliche	WB	137	140	3

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 3" x 3/4"
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 JUN 02 1995

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started May 24 1995
 Date completed May 29 1995

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller.
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 5/30/95

