2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

1" Back

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47634
Permit No.
Basin 162

NOTICE OF INTENT NO. 14657

1. OWNER Mr. Bejar
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1920 E Gamebird

2. LOCATION SE ¼ SE ¼ Sec. 35 T. 20 S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 41-201-23 (Parcel No.) Calvada (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	8	4
Limestone		8	13	5
Clay		13	23	10
Calichie		23	26	3
Clay		26	39	13
Calichie		39	42	3
Clay		42	54	12
Calichie	WB	54	57	3
Clay		57	66	9
Calichie	WB	66	69	3
Clay		69	80	11
Calichie	WB	80	86	6
Clay		86	91	5
Calichie	WB	91	93	2
Clay		93	103	10
Calichie	WB	103	106	2
Clay		105	110	5
Calichie	WB	110	112	2
Clay		112	127	15
Calichie	WB	127	130	3
Clay		130	140	10

RECEIVED
JUN 02 1995
Div. of Water Resources
Branch Office Las Vegas, NV

Date started May 16, 1995
Date completed May 19, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun
By driller performing actual drilling on site or contractor
Date 5/30/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627