2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47635
Permit No.
Basin
NOTICE OF INTENT NO. 14656

1. OWNER Cecil Slaughter
MAILING ADDRESS RKD
ADDRESS AT WELL LOCATION 2251 E. Thousandair

2. LOCATION ~~NE~~ NW ¼ ~~NE~~ NW ¼ Sec. 13 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-581-01 (Parcel No.) Conestoga Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Calichie		5	7	2
Clay		7	10	3
Calichie		10	13	3
Clay		13	24	11
Calichie		24	26	2
Clay		26	43	17
Calichie		43	45	2
Clay		45	51	6
Calichie	WB	51	53	2
Clay		53	69	16
Calichie	WB	69	72	3
Clay		72	81	9
Calichie	WB	81	84	3
Clay		84	93	9
Calichie	WB	93	95	2
Clay		95	106	11
Calichie	WB	106	110	4
Clay		110	122	12
Calichie	WB	122	126	4
Clay		126	137	11
Calichie	WB	137	140	3

RECEIVED
JUN 02 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 16, 19 95
Date completed May 19, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dean (By driller performing actual drilling on site or contractor)
Date 5/30/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627