

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 47636
 Permit No. 1162
 Basin 1

NOTICE OF INTENT NO. 14655

1. OWNER Tony Guerra ADDRESS AT WELL LOCATION 1890 Barnvitch
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 20S N/S R. 52 E County Nye
 PERMIT NO. 28-821-13 Parcel No. _____ Subdivision Name Charleston Park

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	3	3
Caliche		3	5	2
Clay		5	12	7
Caliche		12	14	2
Clay		14	25	11
Caliche		25	28	3
Clay		28	39	11
Caliche		39	46	7
Clay		46	53	7
Caliche	WB	53	55	2
Clay		55	67	12
Caliche	WB	67	73	6
Clay		73	91	18
Caliche	WB	91	93	2
Clay		93	106	13
Caliche	WB	106	113	7
Clay		113	123	10
Caliche	WB	123	129	6
Clay		129	140	11

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1 1/2" x 3"
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 JUN 02 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started May 16 1995
 Date completed May 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HC R 78, Box 90358 Contractor
Pahrump, NV 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 5/30/95