



WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 77639
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14343

1. OWNER Deborah Dopquera ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 3074 Huckelberry st
Pahrump, NV 89041 Pahrump, NV 89041
 2. LOCATION N.E. 1/4 N.W. 1/4 Sec. 29 T. 20 S. N/S R. 53 E. E. Nye County
 PERMIT NO. 30-032-15 Calvada Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|-----|------------|
| Brown Clay | | 0 | 4 | 4 |
| Decomposed Calichia | | 4 | 11 | 7 |
| Calichia | | 11 | 21 | 10 |
| Hard Water Cal. | | 21 | 27 | 6 |
| Decomposed Calichia | | 27 | 50 | 23 |
| Hard Calichia | x | 50 | 57 | 7 |
| Hard Grey Clay | x | 57 | 115 | 58 |
| Brown Clay | x | 115 | 140 | 25 |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1.2 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 | 17 | .188 | 0 | 140 |

Perforations:
 Type perforation Factory
 Size perforation 3 X 4 X 16
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 54' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 6-20, 1995
 Date completed 6-27, 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | 30 | 3 | 1/2 Hr. |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry's Water well Service Contractor
 Address P.O. Box 3392 Contractor
Pahrump, NV 89041
 Nevada contractor's license number 0035901
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1916
 Division of Water Resources, the on-site driller.
 Signed Larry Tuben
 By driller performing actual drilling on site or contractor
 Date _____

