WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47642
Permit No.
Basin 162

NOTICE OF INTENT NO. 13025

1. OWNER R.W. Davies
MAILING ADDRESS 45500 N 28th E. 11
Lancaster, CA 93535

ADDRESS AT WELL LOCATION Lot 606
Dyer St.
Pahrump, NV 89041

2. LOCATION N-E ¼ N-E ¼ Sec. 13 T. 20 S N/S R. 52 E E. Nye County
PERMIT NO. (Issued by Water Resources) 28-703-12 (Parcel No.) Charelston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Dark Calichia		3	10	7
Grey Clay		10	45	35
Brown Clay	X	45	60	15
Grey	X	60	95	35
Brown Clay	X	95	130	35
Grey Clay	X	130	140	10

DCNR/DWR Received JUN 30 1995 LAS VEGAS OFFICE

Date started 6-11, 19 95
Date completed 6-15, 19 95

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	13	1/2 hr.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:
Type perforation Factory
Size perforation 3 x 16 x 4'
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry's Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins (By driller performing actual drilling on site or contractor)
Date 6-8-95

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627