




WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY



Log No. 47648  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

NOTICE OF INTENT NO. 14731

1. OWNER Donald Strain ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_ 1230 E. Pluto St.

2. LOCATION SW 1/4 NW 1/4 Sec. 2 T. 21-S N/S R. 53 E. Nye County  
PERMIT NO. 44-163-24 Parcel No. \_\_\_\_\_ Gamebird Blk: F Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray clay		4	10	6
Brown clay		10	18	8
Limestone		18	22	4
Brown clay & caliche		22	28	6
Limestone		28	38	10
Brown clay	X	38	72	34
Brown clay & caliche		72	92	20
Brown clay		92	103	11
Brown clay & caliche		103	118	15
Brown clay	X	118	140	22

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
12 Inches 0 Feet 140 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
Type perforation Torch Cut  
Size perforation 1 1/2" width 8" long  
From 100 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 140 feet

9. WATER LEVEL  
Static water level 51 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started June 9, 1995  
Date completed June 9, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

Name Jim Pike Well Drilling, LLC Contractor  
Address P.O. Box 56 Contractor  
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 17563A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date June 15, 1995

