




WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.300



Log No. 47653  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

NOTICE OF INTENT NO. 14736

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER David Mc Rae ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ 3101 E. Kellogg Rd.

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T. 21-S N/S R. 54 E. Nye County  
 PERMIT NO. 45-261-13 Parcel No. \_\_\_\_\_ Subdivision Name Green Saddle Ranch

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	10	6
Brown clay & limestone		10	15	5
Brown clay		15	32	17
Limestone		32	36	4
Brown clay & caliche		36	48	12
Limestone		48	52	4
Brown clay & caliche	X	52	74	22
Brown clay		74	92	18
Brown clay & caliche		92	108	16
Brown clay	X	108	140	32

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140


Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/2" width 8" long  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jim Pike Well Drilling, LLC Contractor  
 Address P.O. Box 56 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812  
 Signed Jim A. Pike  
 By driller performing actual drilling on site or contractor  
 Date June 15, 1995



Date started June 14, 1995  
 Date completed June 14, 1995

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>20</u>	<u>4</u>	<u>1/2</u>

