

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26532

1. OWNER JOSE FLORES ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 395 Kimball Dr. Elko, NV 89801

2. LOCATION SW 1/4 SW 1/4 Sec 34 T 34 N 52 R 52 E Elko County
 PERMIT NO. None Issued by Water Resources Parcel No. Parcel D, Lot 2, Blk E Subdivision Name Valley Vista Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy loam</u>		<u>0</u>	<u>16</u>	<u>16</u>
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>16</u>	<u>17</u>	<u>1</u>
<u>Sandy clay</u>		<u>17</u>	<u>105</u>	<u>88</u>
<u>Fine sand (poor quality water)</u>	<input checked="" type="checkbox"/>	<u>105</u>	<u>115</u>	<u>10</u>
<u>Sandy clay</u>		<u>115</u>	<u>142</u>	<u>27</u>
<u>Sand & gravel</u>	<input checked="" type="checkbox"/>	<u>142</u>	<u>157</u>	<u>15</u>
<u>Sandy clay</u>		<u>157</u>	<u>160</u>	<u>3</u>
		<u>T.D. 160</u>		

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 60 Feet
8 Inches 60 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2.0</u>	<u>160</u>

Perforations:
 Type perforation Torch cut
 Size perforation 1/8 x 4
 From 56 feet to 77 feet
 From 128 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co. Contractor
 Address 203 PINE ST. ELKO 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed James V. Muth By driller performing actual drilling on site or contractor
 Date 2-2-95

Date started 1-27, 1995
 Date completed 2-3, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>40</u>	<u>25</u>	<u>1 hr.</u>
	<u>20</u>	<u>4</u>	<u>2 hr.</u>