



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47669
Permit No. _____
Basin 16a

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 14659

1. OWNER Bill Moore ADDRESS AT WELL LOCATION 2420 W. Silversage
MAILING ADDRESS _____
2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 19 S. N/S R. 53 E Me County
PERMIT NO. 29-443-06 Valley View Acres Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Caliche		5	11	6
Clay		11	17	6
Caliche		17	22	5
Clay		22	29	7
Caliche		29	32	3
Clay		32	40	8
Caliche		40	43	3
Clay		43	52	9
Caliche	WB	52	57	5
Clay		57	69	12
Caliche	WB	69	72	3
Clay		72	80	8
Caliche	WB	80	82	2
Clay		82	92	10
Caliche	WB	92	95	3
Clay		95	100	5

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 100 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>.188</u>	<u>0</u>	<u>100</u>

Perforations:
Type perforation Factory Saw cut
Size perforation 3/8" x 3"
From 80 feet to 100 feet
From 100 feet to 80 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____



Date started May 23 1995
Date completed May 27 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041

Nevada contractor's license number 30880
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan
By driller performing actual drilling on site or contractor

Date 6/14/95