

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15885

1. OWNER Layne + Jane House ADDRESS AT WELL LOCATION 3245 Potbelly Rd  
 MAILING ADDRESS 3245 Potbelly Rd Winnemucca, NV 89445 Winnemucca, NV Humboldt County  
 2. LOCATION NE 1/4 NE 1/4 Sec. 30 T. 35 S. R. 39 E.  
 PERMIT NO. N/A 14-142-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Gravel		0	80	
SAND + Gravel		80	100	
SAND Gravel 60% Clay 40%		100	130	
SAND Gravel 80% Clay 20%		130	150	

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 150 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>+1</u>	<u>150</u>

Perforations:  
 Type perforation FACTORY CUT  
 Size perforation 3/32  
 From 120' feet to 150' feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50' feet to 150' feet

Date started 8-19, 1994  
 Date completed 8-22, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow No G.P.M. 20 P.S.I.  
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Contractor  
 Address 10760 Grass Valley Road Contractor  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 024167  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-26-94