WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
#T-2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47709
Permit No. 61158T
Basin 212

NOTICE OF INTENT NO. 16120

1. OWNER Las Vegas Ineternational Speedway
MAILING ADDRESS 6000 N Las VEGAS Blvd
Las Vegas NV 89119

ADDRESS AT WELL LOCATION 6000 N Las Vegas Blvd

2. LOCATION SW ¼ NW ¼ Sec. 25 T 195 S R 62 E Clark County
PERMIT NO. 61158 T (Issued by Water Resources) 52023000 2 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel		0	10	10
Brown Clay		10	200	190
Sand		200	265	65
/ Clay		265	345	80
Gravel		345	380	35
/ Sand & Gravel		380	435	55
Lime mud & Red clay		435	465	30
Sand & lime mud		465	555	90
Red brown clay		555	565	10
Sand		565	660	95

Date started 4-30, 19 95
Date completed 6-7, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
82		24

8. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 660 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 1/2 Inches		0 Feet	660 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	24lb	1/4	+1	660

Perforations:
Type perforation Screen
Size perforation
From 293 to 313 feet to 330 to 340 feet
From 430 feet to 480 feet
From 490 feet to 510 feet
From 530 feet to 580 feet
From 590 feet to 620 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 660 feet

9. WATER LEVEL
Static water level 186 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc (Contractor)
Address 4185 W Harmon (Contractor)
Las Vegas nv 89103
Nevada contractor's license number issued by the State Contractor's Board 4286 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1987
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date 6-28-95

DCNR/DWR Received JUL 5 1995 LAS VEGAS OFFICE

JUL 19 A 8:52 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627