



WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 47715  
Permit No. 162  
Basin 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16144

1. OWNER Bill Moore ADDRESS AT WELL LOCATION 2721 W. Silver Sage  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 19 S N/S R 53 E Nye County  
PERMIT NO. 29-461-02 Valley View Acres Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Caliche		8	13	5
Clay		13	22	9
Caliche		22	34	12
Clay		34	31	7
Caliche		31	33	2
Clay		33	44	11
Caliche		44	46	2
Clay		46	53	7
Caliche	WB	53	55	2
Clay		55	61	6
Caliche	WB	61	64	3
Clay		64	69	5
Caliche	WB	69	72	3
Clay		72	76	4
Caliche	WB	76	81	5
Clay		81	92	11
Caliche	WB	92	94	2
Clay		94	100	6

8. WELL CONSTRUCTION  
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)  
From 0 To 100  
12 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>100</u>

Perforations: Factory Sawcut  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 80 feet to 100 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 100 feet

9. WATER LEVEL  
Static water level 4.8 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started May 23 19 95  
Date completed May 26 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge

Name Great Basin Drilling Contractor  
Address HCR 78 Box 80358 Contractor  
Yahrump, NV. 89041  
Nevada contractor's license number 30880  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
Signed Thomas Dun  
By driller performing actual drilling on site or contractor  
Date 6/14/95

