WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47728
Permit No.
Basin 162

NOTICE OF INTENT NO. 16145

1. OWNER Barry Holland
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4301 Retread

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 20S N/S R. 52 E. Nye County
PERMIT NO. 28-132-08 (Issued by Water Resources) Parcel No. Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	7	3
Clay		7	17	10
Calichie		17	21	4
Clay		21	32	11
Calichie		32	35	3
Clay		35	44	9
Calichie		44	46	2
Clay		46	52	6
Calichie	WB	52	57	5
Clay		57	68	11
Calichie	WB	68	73	5
Clay		73	92	19
Calichie	WB	92	103	11
Clay		103	114	11
Calichie	WB	114	119	5
Clay		119	128	9
Calichie	WB	128	132	4
Clay		132	140	12

SCANNED/WR
Received
JUL 6 1995
LAS VEGAS OFFICE

Date started May 25, 19 95
Date completed May 30, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/6/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627