

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 47743, 47744
 Permit No. _____
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25579

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 29 BARRICK GOLDSTRIKE MINE
ELKO, NEVADA 89801

2. LOCATION SE 1/4 SE 1/4 Sec. 5 T. 36 N. S. R. 49 E. EUREKA County
 PERMIT NO. M/O-795 Parcel No. N/A Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY, RED & BLACK ROCK		0	100	100
GRAY, RED & BLACK ROCK		100		
WITH TAN CLAY	2GPM	600	500	
GREEN, GRAY ROCK SOME CLAY		600	650	50
BLACK BED ROCK		650	850	200
FRACTURED GRAY ROCK	10 GPM	850	1,000	150
GRAY, RED & BROWN ROCK	10 GPM	1,000	1,350	350
GRAY & BROWN ROCK	15 GPM	1,350	1,980	630
GRAY, BROWN ROCK -	15 GPM	1,980	2,040	60
SOME CLAY				
GRAY, BLACK & BROWN	15 GPM	2,040	2,140	100
ROCK				
GREEN & GRAY ROCK	15 GPM	2,140	2,170	30
BROWN & BLACK ROCK	15 GPM	2,170	2,200	30
BROWN, BLACK ROCK,		2,200		
SOME GREEN CLAY			2,300	100

8. WELL CONSTRUCTION
 Depth Drilled 2,300 Feet Depth Cased 2,300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0	35
6 1/2 Inches	35	2,300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22	.250	0	35
1 1/4	3	SCHED. 80	0	420
2	5	.218	0	2,200

Perforations:
 Type perforation DRILL HOLES
 Size perforation 1/8"
 From 1 1/4" 420 feet to 480 feet
 From 2 2,200 feet to 2,300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 400' / 2,170 feet to 480' / 2,300 feet

9. WATER LEVEL
 Static water level 340' & 927' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING
 Contractor
 Address 2286 WEST 1500 SOUTH
 Contractor
SALT LAKE CITY, UTAH 84104
 Nevada contractor's license number 0021976
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1716
 Division of Water Resources, the on-site driller
 Signed DAVID HAAS
 By driller performing actual drilling on site or contractor
 Date _____

Date started NOVEMBER 11, 1994
 Date completed NOVEMBER 17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)